


- NOTES:
1. ENCLOSURE TO BE LABELED UL TYPE 4 & 12.
 2. ENCLOSURE IS 16GA. STEEL.
 3. ENCLOSURE PROVIDED WITH 16GA. WHITE PAINTED PRE-PUNCHED SUB PANEL.
 4. REFER TO DRAWING D 5491 1001-003.
 5. SCE-CONCEALED HINGE USED ON DOOR.
 6. GROUND STUDS ON BODY AND DOOR.
 7. SUB PANEL IS MOUNTED ON 1/4-20 X 9/16 HIGH B50.S.
 8. SCE-MINQB 1/4 TURN LATCHES TWO PLACES ON DOOR.
 9. .875 PUSH BUTTON HOLES (WITH HOLE PLUGS PROVIDED BY SCE) IN RIGHT FLANGE.
 10. POUR IN PLACE GASKET IS USED ON INSIDE OF DOOR FOR SEALING.
 10. ALL SEAMS WELDED AND GROUND SMOOTH.

REV. LET.	REVISIONS	DATE	REV. OR APPD. BY	SCALE	1/8"	DIMENSIONS ARE IN INCHES
B	ADDED KEY SLOT FOR 3/8" BOLT	4/4/05	TSP	SCALE	1/8"	DIMENSIONS ARE IN INCHES
C	ADDED REFERENCE TO D 5491 1001-006 IN NOTE 3.	12/28/05	MRH	Material:	12.5X24X7.125	TYPE 4 & 12
				Finish:	ANSI 61 LIGHT GREY	
				STANDARD TOLERANCES ANGLES		
				2 PL. DEC.	±.030	±1°
				3 PL. DEC.	±.030	±1°

DO NOT SCALE DRAWING

THIS DRAWING IS THE PROPERTY OF ABB Inc. AND CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, COPIED OR DISCLOSED WITHOUT THE AUTHORIZATION BY ABB Inc.



DATE	3/24/05
DRAWN	DW
CHK'D	
APP'R'D	
SHEET	1 OF 1

REV.	C	TITLE	UL TYPE 4 & 12 ENCLOSURE
SIZE	A	DRAWING NUMBER	D 5491 0001-012

PART